



Raptor Guard™
Nesting Diverters



Raptor Guard™
Spike Perching Deterrents



Raptor Guard™
"X" Perching Deterrents

Minimum air gap reference for installation:

System kV	Air gap	
	in	cm
≤ 15	5 in	12.7 cm
≤ 25	6.5 in	16.51 cm
≤ 35	8.5 in	21.59 cm
≤ 44	10 in	25.4 cm
≤ 69	15 in	38.1 cm

> Air gap lengths listed are to be used for reference of Power Line Sentry Raptor Guard™ "X", Spikes, and Nest Diverters.

> Please refer to *NESC Section 235-6* for more information.

> Please note that there are several other factors to be considered in the calculations that can affect the distance (i.e., altitude, contamination level, humidity, etc). Our recommended distances do not include these factors.